



PUBLIC UTILITIES REGULATORY COMMISSION

ENCLAVE POWER COMPANY (EPC) KEY REGULATORY INDICATORS

2023 Third Quarter Performance

| INDICATOR | UNIT | Q3 |
|-----------------------------------|----------------|--------------|
| MAXIMUM DEMAND | MW | 47.83 |
| Commercial Losses | % | 0.24% |
| Technical Losses | % | 0.21% |
| SYSTEM (TOTAL LOSSES) | % | 0.45% |
| Total Electricity Purchases (GWh) | GWh | 64.32 |
| Total Electricity Sales (GWh) | GWh | 64.02 |
| NUMBER OF CUSTOMERS | | |
| Metro | Number | 165 |
| SAIDI | | |
| Metro | Hours/Customer | 6.00 |
| SAIFI | | |
| Metro | No./Customer | 0.97 |
| CAIDI | | |
| Metro | Hours/Customer | 6.20 |
| METERING PERFORMANCE | | |
| Number of Meters | | |
| Special Load Tariff (SLT) | GWh | 165 |
| Meter Age Distribution | | |
| 0 to < 5 years | Number | 140 |
| 5 to < 10 years | Number | 25 |