



PUBLIC UTILITIES REGULATORY COMMISSION

KEY REGULATORY INDICATORS FOR ENCLAVE POWER COMPANY (EPC)

2025 Second Quarter Performance

INDICATOR	UNIT	Q2
MAXIMUM DEMAND	MW	60.93
Commercial Losses	%	0.25%
Technical Losses	%	0.29%
SYSTEM (TOTAL LOSSES)	%	0.54%
Total Electricity Purchases (GWh)	GWh	84.74
Total Electricity Sales (GWh)	GWh	84.28
NUMBER OF CUSTOMERS		
Metro	Number	186
SAIDI		
Metro	Hours/Customer	2.30
SAIFI		
Metro	No./Customer	0.21
CAIDI		
Metro	Hours/Customer	10.86
METERING PERFORMANCE		
Number of Meters		
Special Load Tariff (SLT)	GWh	186
Meter Age Distribution		
0 to < 5 years	Number	186